



*Southern Pipe, Inc.*

P. O. Box 606, 135 Random Drive, New London, NC 28127  
Phone: 704-463-5202 Fax: 704-463-5203 www.southern-pipe.com

## Type “A”

**TYPE “A” PVC CONDUIT IS INTENDED FOR ENCASEMENT IN  
CONCRETE IN ANY LOCATION**

Size	Part #	Description	Min Wall	O.D.	Weight per 100 feet	Pallet Quantity
2”	94620	20 FT/BE	0.100	2.36	46	2800
2 1/2”	94625	20 FT/BE	0.110	2.86	65	1860
3”	94630	20 FT/BE	0.125	3.49	85	1760
3 1/2”	94635	20 FT/BE	0.145	3.95	103	1260
4”	94640	20 FT/BE	0.150	4.45	132	1140

*Southern Pipe* Type “A” is manufactured in accordance with the following industry standards.

Underwriters Laboratory, Inc. ® (UL)

651-A



MANUFACTURER OF QUALITY PVC ELECTRICAL CONDUIT PRODUCTS