


Southern Pipe	Trade	T Min	OD	ID	E	B	D Min	L
Part Number	Size	Wall Thickness	Outside Diameter	Inside Diameter	Bell Entrance ID	Bell Bottom ID	Bell Depth	Total Length
52505	1/2"	0.147	0.840	0.502	0.852	0.835	1.500	240
52508	3/4"	0.154	1.050	0.698	1.064	1.046	1.500	240
52510	1"	0.179	1.315	0.910	1.330	1.310	1.750	240
52512	1 1/4"	0.191	1.660	1.227	1.677	1.655	2.000	240
52515	1 1/2"	0.200	1.900	1.446	1.918	1.894	2.125	240
52520	2"	0.218	2.375	1.881	2.393	2.369	2.500	240
52525	2 1/2"	0.276	2.875	2.250	2.890	2.868	3.000	240
52530	3"	0.300	3.500	2.820	3.525	3.492	3.625	240
52535	3 1/2"	0.318	4.000	3.280	4.015	3.992	3.875	240
52540	4"	0.337	4.500	3.737	4.525	4.491	4.125	240
52550	5"	0.375	5.563	4.713	5.593	5.553	4.750	240
52560	6"	0.432	6.625	5.646	6.658	6.614	5.750	240

 Listed 651
 NEMA TC 2
 Sunlight Resistant
 See NEC Article 352 for Usage

RUS Listed
 NEMA TC 18
 90° C Wire

FOR EASY IDENTIFICATION, ALL SCHEDULE80 CONDUIT IS MARKED WITH A YELLOW *Powerline*® from spigot to bell



Schedule 80 Rigid Non-Metallic PVC Conduit - 20'

UNLESS OTHERWISE SPECIFIED
 DIMENSIONS ARE IN INCHES
 All Dimensions are Nominal

	NAME	DATE
DRAWN	K. Mitchell	04/01/13
CHECKED		
ENG APPR		
FILE: SCH 80 20 FOOT.dft		REV 10