


Southern Pipe	Trade	T Min	OD	ID	E	B	D Min	L
Part Number	Size	Wall Thickness	Outside Diameter	Inside Diameter	Bell Entrance ID	Bell Bottom ID	Bell Depth	Total Length
51505	1/2"	0.147	0.840	0.502	0.852	0.835	1.500	120
51508	3/4"	0.154	1.050	0.698	1.064	1.046	1.500	120
51510	1"	0.179	1.315	0.910	1.330	1.310	1.750	120
51512	1 1/4"	0.191	1.660	1.227	1.677	1.655	2.000	120
51515	1 1/2"	0.200	1.900	1.446	1.918	1.894	2.125	120
51520	2"	0.218	2.375	1.881	2.393	2.369	2.500	120
51525	2 1/2"	0.276	2.875	2.250	2.890	2.868	3.000	120
51530	3"	0.300	3.500	2.820	3.515	3.492	3.625	120
51535	3 1/2"	0.318	4.000	3.280	4.015	3.992	3.875	120
51540	4"	0.337	4.500	3.737	4.515	4.491	4.125	120
51550	5"	0.375	5.563	4.713	5.593	5.553	4.750	120
51560	6"	0.432	6.625	5.646	6.658	6.614	5.750	120

 Listed 651  
 NEMA TC 2  
 Sunlight Resistant  
 See NEC Article 352 for Usage

RUS Listed  
 NEMA TC 18  
 90° C Wire

FOR EASY IDENTIFICATION, ALL SCHEDULE80 CONDUIT IS MARKED WITH A YELLOW *Powerline*® from spigot to bell



Schedule 80 Rigid Non-Metallic PVC Conduit - 10'

UNLESS OTHERWISE SPECIFIED  
 DIMENSIONS ARE IN INCHES  
 All Dimensions are Nominal

	NAME	DATE
DRAWN	K. Mitchell	04/01/13
CHECKED		
ENG APPR		
FILE: SCH 80 10 FOOT.dft		REV 10